

# East Sevier County Utility District 2025 Water Quality Report

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts and the commitment we have made to protect our water resources.

## What is the source of my water?

Your water is supplied by treated groundwater (wells). They are located in the Chestnut Hill Quadrangle of English Mountain. Our goal is to protect our water from contaminants, and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The East Sevier County Utility District sources rated are rated as slightly susceptible to potential contamination. An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

## Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

*Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.*

**For more information about your drinking water, please call East Sevier County U.D. at 865-453-6704.**

## How can I get involved?

Our Water Board meets on the fourth Thursday of each month at 5:00 p.m. at 130 Gary Wade Blvd. Sevierville, TN 37862. Please feel free to participate in these meetings. For additional information, please call 865-453-6704.

## Is our water system meeting other rules that govern our operations?

ESCUD routinely monitors for constituents in your drinking water according to Federal and State regulations. We're pleased to report that our drinking water is safe and meets federal/state requirements. This report shows our water quality and what it means. The attached Water Quality Data table shows the results of monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022.

## Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. ESCUD's water treatment processes are designed to reduce any such substances to levels well below any health concern. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Lead in Drinking Water

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. East Sevier County Utility District is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact East Sevier County Utility District at 865-453-6704. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## Lead Service Line Inventory

A Lead Service Line Inventory has been completed for our system and is accessible by contacting our office during regular business hours.

**Water System Security**

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities to 865-453-6704.

**Pharmaceuticals In Drinking Water**

Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at <https://tdeconline.tn.gov/rxtakeback/>

# Water Quality Data

## What does this chart mean?

- MCLG - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MCL - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- MRDL: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- MRDLG: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- AL - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- Below Detection Level (BDL) - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- Parts per million (ppm) or Milligrams per liter (mg/l) – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- RTCR – Revised Total Coliform Rule. This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.
- Non-Detects (ND) - laboratory analysis indicates that the contaminant is not present.

| Contaminant                     | Violation Yes/No | Level Detected                    | Range of Detections | Date of Sample | Unit Measurement | MCLG | MCL        | Likely Source of Contamination                                                                         |
|---------------------------------|------------------|-----------------------------------|---------------------|----------------|------------------|------|------------|--------------------------------------------------------------------------------------------------------|
| Total Coliform Bacteria (RTCR)  | No               | 0                                 | 0                   | 2025           |                  | 0    | TT Trigger | Naturally present in the environment                                                                   |
| Copper <sup>1</sup>             | No               | 90 <sup>th</sup> %<br>=<br>0.0974 | 0.0115-0.101        | 2024           | ppm              | 1.3  | AL=1.3     | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead <sup>1</sup>               | No               | 90 <sup>th</sup> %<br>=<br>1.68   | < 1.0 – 3.19        | 2024           | ppb              | 0    | AL=15      | Corrosion of household plumbing systems, erosion of natural deposits                                   |
| Sodium                          | Yes              | 14.6                              | 5.81-14.6           | 2021           | ppm              | N/A  | N/A        | Erosion of natural deposits; used in water treatment                                                   |
| TTHM<br>[Total trihalomethanes] | Yes              | BDL                               | BDL*                | 2024           | ppb              | N/A  | 80         | By-product of drinking water chlorination                                                              |
| Haloacetic Acids (HAA5)         | Yes              | BDL                               | BDL*                | 2024           | ppb              | N/A  | 60         | By-product of drinking water disinfection.                                                             |
| Nitrate                         | No               | < 0.1                             | <0.1-<0.1           | 2025           | ppm              | 10   | 10         | Runoff from fertilizer use, leaching from septic tanks, sewage, erosion from natural deposits          |
| Contaminant                     | Violation Yes/No | Level Detected                    | Range of Detections | Date of Sample | Unit Measurement | MRDL | MRDL G     | Likely Source of Contamination                                                                         |
| Chlorine                        | No               | 1.19 Avg.                         | 0.53-1.73           | 2025           | ppm              | 4    | 4          | Water additive used to control microbes.                                                               |

<sup>1</sup> During the most recent round of lead and copper testing, 0 out of 10 households sampled contained concentrations exceeding the action level.

\*We are only required to collect one sample from a single location.

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring Requirement Not Met for *The East Sevier County Utility District*

The East Sevier County Utility District violated drinking water standards. Even though this was not an emergency, you as a customer have a right to know what happened and what we are doing to correct this situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2024, 2025, and 2026 we did not monitor for Sodium, Consumer Confidence Report Rule, Groundwater Rule, Total Trihalomethanes, and Haloacetic Acids, and Revised Total Coliform Rule as required and therefore cannot be sure of the quality of our drinking water during that time.*

#### What should you do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not test for, how often we are supposed to sample, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples will be taken.

| Contaminant                                                                                                                                                                                                                                                                     | Required Sampling Frequency       | Number of Samples Required     | When Samples Should Have Been Taken | When Samples Were Taken                          |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------|--------------------------------|-------------------------------------|--------------------------------------------------|
| Sodium                                                                                                                                                                                                                                                                          | 1 Sample per Year per Entry Point | 2                              | 2024                                | No Sodium Samples were taken as required.        |
| The 2024 CCR did not contain a 2024 Lead & Copper reporting violation for not providing 2024 customer notice to customers within the 30 days of receiving the laboratory results. The 2024 CCR did not contain ground water rule violations for January 2024 and February 2024. | Reporting Violation               | N/A                            | 202 on CCR                          | N/A                                              |
| Groundwater Rule Violation: Failure to Submit CN 1201                                                                                                                                                                                                                           | Monthly                           | January 2024 and February 2024 | January 2024 and February 2024      | N/A                                              |
| TTHM (Total trihalomethanes)                                                                                                                                                                                                                                                    | 1 Sample per Year                 | 1                              | 9/10/2025                           | 12/19/2024                                       |
| Haloacetic Acids (HAA5)                                                                                                                                                                                                                                                         | 1 Sample per Year                 | 1                              | 9/10/2025                           | 12/19/2024                                       |
| Revised Total Coliform Rule (Bacteriological Sampling)                                                                                                                                                                                                                          | 1 sample per Month                | 1                              | January 2026                        | No Bacteriological Sample was taken as required. |

**What is being done?**

Current management/staff is working to review sampling requirements and coordinate with our contract laboratory to ensure compliance with drinking water regulations/requirements.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in condos, rentals, apartments, etc.). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by *the*:

East Sevier County Utility District  
1529 Alpine Drive  
Sevierville, TN 37876  
State Water System ID#: TN0000618

Date Distributed: June 2026 by CCR

